

WINGERTER LABORATORIES, INC.

Engineering Testing & Inspection Services
1820 N.E. 144 Street, North Miami, FL 33181
Telephone (305) 944-3401 Fax (305) 949-8698

REPORT OF TESTING

CLIENT:	Blue World Crete	REPORT NO:	1
PROJECT:	Product Evaluation	ORDER NO:	11-1269
LOCATION:	Wingert Laboratories Inc., North Miami, Fl	PAGE NO.:	1 of 1

Sample Description: New Cementacious Material

ASTM D 543

Start Soak	9/21/2011	3:00 PM
End Soak	9/28/2011	3:00 PM
Total Time	168 Hrs	

Solution	Strength	% of Loss
Transformer Oil	N/A	1.9
Fuel Oil	N/A	1.5
Hydrochloric Acid	0.2N	1.7
Acetic Acid	5%	1.8
Sulfuric Acid	0.1N	2.1
Sodium Hydroxide	0.1N	2.9
Sodium Chloride	5%	2.4
Sodium Sulfate	0.1N	4.7
Sodium Carbonate	0.1N	1.7

Charges: 9 ASTM D 543

Respectfully Submitted,
WINGERTER LABORATORIES, INC.
No. 34715
STATE OF FLORIDA
Robert H. Schuler, P.E., P.G.
FE License No. 34715
10-12-11

The original of this report was signed and sealed by the above Registered Professional Engineer in accordance with Rule 61G15 - 18.001 of Florida Administrative Code. As a mutual protection to clients, the public and ourselves, all reports are submitted as confidential property of clients and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.