

WINGERTER LABORATORIES, INC.

Engineering Testing & Inspection Service

1820 N. E. 144th Street, North Miami, FL 33181

Phone: (305) 944-3401 Fax: (305) 949-8698

CONCRETE LABORATORY TEST REPORT

CLIENT: Blue World Crete America, Inc. REPORT NO.: 1
PROJECT: QC 2011 ORDER NO.: 11-1230
LOCATION: WLI, North Miami, FL TESTED BY: L. Rodriguez


SAMPLE ID #: GB II FIELD MARK #: Aug59
MIX ID #: Geo-Blue Crete II

TEST OF TENSILE STRENGTH OF CONCRETE

Sample No.	Weight (Lbs.)	Diameter (Inches)	Area (Sq. Inches)	Date Made	Date Tested	Age Days	Total Load (Lbs.)	PSI
1	8.00	4.0	12.57	08-08-11	08-11-11	3	7,840	69
2	8.00	4.0	12.57	08-08-11	08-16-11	8	7,970	71
3	8.00	4.0	12.57	08-08-11	08-22-11	14	10,000	88
4	8.00	4.0	12.57	08-08-11	09-06-11	29	11,410	101

Remarks: Cylinders cast & delivered by client. On August 10,2011.

All field and laboratory tests and sample curing performed in accordance with applicable ASTM Test Methods. Cylinders are 4" x 8", unless otherwise indicated. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



Respectfully submitted,
WINGERTER LABORATORIES, INC.
Robert H Schuler, P.E., P.G.
Fla. License No.: 34715
9-6-11

Picture of 29 Day:

The original of this report was signed and sealed by the above registered engineer in accordance with Rule 61G15-18.011 of the Florida Administrative Code. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of client, and authorization for publication of statements, conclusions or extracts from or regarding our report is reserved pending our written approval.