

WINGERTER LABORATORIES, INC.

Engineering Testing & Inspection Services
1820 N.E. 144th Street, North Miami, FL 33181
Phone (305) 944-3401 Fax (305) 949-8698

REPORT OF: ABSORPTION TEST ON CYLINDERS


Client: Blue World Crete America, LLC **Report No:** 1
Project : Quality Control 2011 **Order No:** 11-1230
Location : WLI, North Miami, FL **Page No:** 1 of 1
Description : 3" x 6" Cylinder **Tested By:** M. Major

Date Received: 08-10-11 **Lab No.:** 420

Test Method: Testing Concrete ASTM FM 3-C-497-05
Method for determination of Water Absorption

Sample ID	Date Cast	% Absorption	Age (Days)	Date Tested
GB II	8/8/2011	13.80%	14	8/22/2011
GB II	8/8/2011	5.42%	28	9/6/2011

Charges: 2 Test

Respectfully Submitted,
WINGERTER LABORATORIES, INC.

Robert H. Schuler, P.E., P.G.
Registration No. 34715
9-24-11

The original of this report was signed and sealed by the above Registered Professional Engineer in accordance with Rule 61G15 - 18.011 of Florida Administrative Code. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

WINGERTER LABORATORIES, INC.

Engineering Testing & Inspection Services
1820 N.E. 144th Street, North Miami, FL 33181
Phone (305) 944-3401 Fax (305) 949-8698

REPORT OF: ABSORPTION TEST ON CYLINDERS

Client: Blue World Crete America, LLC
Project : Quality Control 2011
Location : WLI, North Miami, FL
Description : 3" x 6" Cylinder

Report No: 2
Order No: 11-1230
Page No: 1 of 1
Tested By: M. Major

Date Received: 08-24-11


Lab No.: 452

Test Method:

Testing Concrete ASTM FM 3-C-497-05
Method for determination of Water Absorption

Sample ID	Date Cast	% Absorption	Age (Days)	Date Tested
GB II	8/19/2011	12.20%	14	9/2/2011
GB II	8/19/2011	8.03%	28	9/16/2011

Charges: 2 Test



Respectfully Submitted,
WINGERTER LABORATORIES, INC.

[Signature]
Robert H. Schuler, P.E., P.G.
Registration No. 34715

The original of this report was signed and sealed by the above Registered Professional Engineer in accordance with Rule 61G15 - 18.011 of Florida Administrative Code. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.